

Review of: "Socioeconomic Impacts of Hybrid Pico Hydro-Solar Generation System Implementation in Sitio Singawan, Barangay Umiray, Municipality of Dingalan, Aurora, Philippines"

Jamal Elmansour¹

¹ Université Chouaib Doukkali

Potential competing interests: No potential competing interests to declare.

Interesting subject beyond some questions

1- missing of project picture or layout. Showing the diagram help to begger undertand the topic.

2- Pelton turbine is widely used for high altitude. The choice of pelton for low altitude is maybe a wrong choice. Kaplan is used for low altitude and high water flow.

3- The calculation of the revenues is based on a simple estimations.the authors does not take into the effect of the actualization rate. He shoud start evaluating the net present value.

4- considering pumping mode can improve the profitability of the system.